



State of New Jersey  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 Mail Code 401-04Q  
 Division of Water Supply & Geoscience  
 Water System Operations Element  
 Bureau of Safe Drinking Water  
 401 E. State Street - P.O. Box 420  
 Trenton, New Jersey 08625-0420  
 Tel #: (609) 292-5550 - Fax #: (609) 292-1654  
<http://www.nj.gov/dep/watersupply/>

CATHERINE R McCABE  
 Acting Commissioner

PHILIP D. MURPHY  
 GOVERNOR

SHEILA Y. OLIVER  
 LT. GOVERNOR

CCR Year: 2018  
 (2017 data)

2018 Consumer Confidence Report (CCR) Certification Form

PWS ID# NJ 1023002

Community Water System Name: Borough of Stockton

Community Water System Address: 2 South Main, Stockton NJ 08551

1. CCRs must be mailed or electronically delivered to all bill-paying customers by July 1<sup>st</sup>. Provide date(s) of distribution: Mailed 6/20/1018

2. Please check the distribution method(s) utilized to reach your bill-paying customers.

Mailed the CCR

Mailed the direct URL of the CCR

Embedded in an email message

Attached as a PDF file in an email message

Provided the website link (URL) in an email message

Provided information on how a hardcopy of the CCR can be obtained

3. If the CCR was provided to customers electronically, provide the direct URL:

\_\_\_\_\_

4. Community Water Systems serving greater than or equal to 100,000 persons must post their CCR on the Internet. Date posted on the Internet and the URL: N/A

\_\_\_\_\_

5. Community Water Systems must make a good faith effort to reach all appropriate non-bill paying customers. Check all of the methods that were utilized by your community water system.

Posted the CCR in public places (attach a list of locations)

Delivered copies of the CCR to several single bill addresses serving a significant number of people (example: apartment buildings, businesses and companies).

Advertised the availability of the CCR in news media (attach copy of announcement)

Published the CCR in a local newspaper (copy enclosed)

Other (List): \_\_\_\_\_

6. If your Community Water System sells water to another Community Water System, list the name and PWSID Number of the Community Water System(s) and the date the information was provided (due no later than April 1<sup>st</sup> unless mutually agreed upon by both systems):

N/A

7. Is the CCR being utilized to satisfy a Public Notice requirement pertaining to N.J.A.C. 7:10-7.4 for iron, manganese, or sodium?  No/ Yes (circle one)

8. Is the CCR being utilized to satisfy a Tier 3 Public Notice requirement?  No/ Yes (circle one)  
NOTE: If you circled "Yes", 1.) Be sure to submit the PN Certification Form for any Tier 3 PN requirement not previously submitted to DEP, 2.) Be sure to include the necessary standard language for a reporting violation, found at 40 CFR 141.205(d).

9. Check all distribution method(s) for the submittal to the Bureau of Safe Drinking Water (Bureau)\*.

Attached as a PDF file in an email message

Provided the website link (URL) in an email message

Mailed the CCR\*

**\* NOTE: A non-submittal or late submittal to the Bureau will result in a reporting violation. As such, we recommend that you submit a copy using a means that can document the date of Bureau receipt, such as by email or by Certified mail.**

10. The Certification below must be completed by the Community Water System.

I certify that the above referenced community water system has distributed the CCR in accordance with all applicable regulations. Furthermore, I certify that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state.

Signature: [Signature] Date: 4/18/2018

Print Name: GREGORY S. ENT Title: LICENSED OPERATOR

PWSID #: 1023001 Water System Name: BORONGIA @ STONINGTON

Email Address: WATEROPERATOR@STONINGTONBORONGIA.NJ.US

Phone Number: 609.397.0070 Fax Number: 609.397.0070

# Annual Drinking Water Quality Report

## Stockton Borough Water Department

For the Year 2018, Results from the Year 2017

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

Our water source is wells. Our two wells draw groundwater from the Stockton Formation, which is a fractured bedrock aquifer system. Aquifer is another name for water contained in the rock and soil. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at [www.state.nj.us/dep/swap](http://www.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system at 609-397-0070 to obtain information regarding your water system's Source Water Assessment. This water system's source water susceptibility ratings, and a list of potential contaminant sources is included.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants:</b>						
Combined Radium 228 & 226 Tested Results Yr. 2012	N	Range = 1.5 Highest detect = 1.5	pCi/l	0	N/A	Erosion of natural deposits
<b>Inorganic Contaminants:</b>						
Arsenic Test results Yr. 2015	N	Range = 2.6 - 3.1 Highest detect = 3.1	ppb	N/A	5	Erosion of natural deposits; runoff from orchards from glass and electronics production wastes
Barium Test Results Yr. 2015	N	Range = 0.16 - 0.18 Highest detect = 0.18	ppm	2	2	Discharge of drilling wastes; discharge from refineries; erosion of natural deposits
Chromium Test results Yr. 2015	N	Range = ND - 0.6 Highest detect = 0.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Test Results December 2017 Result at 90 <sup>th</sup> Percentile	N	0.56 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride Test results Yr. 2015	N	Range = ND - 0.06 Highest detect = 0.06	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer aluminum factories
Lead Test Results December 2017 Result at 90 <sup>th</sup> Percentile	N	3.9 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Mercury (inorganic) Test results Yr. 2015	N	Range = ND - 0.08 Highest detect = 0.08	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from

Nickel Test results Yr. 2015	N	Range = 0.8 – 1.7 Highest detect = 1.7	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen) Test Results Yr. 2017	N	Range = 1.8 – 2.0 Highest detect = 2.0	ppm	10	10	Runoff from fertilizer use; leaching from septic sewage; erosion of natural deposits
Selenium Test results Yr. 2015	N	Range = 1.7 Highest detect = 1.7	ppb	50	50	Discharge from petroleum and metal refineries of natural deposits; discharge from mines
Thallium Test results Yr. 2015	N	Range = ND – 0.01 Highest detect = 0.01	ppb	0.5	2	Leaching from ore-processing sites; discharge electronics, glass, and drug factories
<b>Disinfection Byproducts:</b>						
TTHM Total Trihalomethanes Test results Yr. 2017	N	Range = 1 - 3 Highest detect = 3	ppb	N/A	80	By-product of drinking water disinfection
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine – Test results Yr. 2017		Average = 0.7 ppm		4.0 ppm		4.0 ppm

The Stockton Water Department routinely monitors for constituents in your drinking water according to Federal and State laws. The table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup> 2017. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Stockton Borough Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, synthetic organic chemicals and volatile organic chemicals. Our system received monitoring waivers for all of these types of contaminants.

## DEFINITIONS

In the "Test Results" table you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) - the concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Recommended Upper Limit - (RUL) Recommended maximum concentration of secondary contaminants. RUL's are recommendations, not mandates.

Secondary Contaminant - Substances that do not have an impact on health. Secondary contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

If you have any questions about this report or concerning your water utility, please contact Greg Ent at 609-397-0070. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings. Meetings are held at Borough Hall, 2 South Main Street, on the last Monday of each month, at 7:30 p.m.

Please call our office if you have questions.

## Stockton Water Department - PWSID # NJ1023001

Stockton Water Department is a public community water system consisting of 2 wells.

This system's source water comes from the following aquifer: Stockton Formation

### Susceptibility Ratings for Stockton Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfecti Byprodu Precurso		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	
Wells - 2			2	1	1				2			2		2			2		2					2

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.



State of New Jersey  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 Mail Code 401-04Q  
 Division of Water Supply & Geoscience  
 Water System Operations Element  
 Bureau of Safe Drinking Water  
 401 E. State Street - P.O. Box 420  
 Trenton, New Jersey 08625-0420  
 Tel #: (609) 292-5550 - Fax #: (609) 292-1654  
<http://www.nj.gov/dep/watersupply/>

PHILIP D. MURPHY  
 GOVERNOR

SHEILA Y. OLIVER  
 LT. GOVERNOR

CATHERINE R McCABE  
 Acting Commissioner

CCR Year: 2018  
 (2017 data)

2018 Consumer Confidence Report (CCR) Certification Form

PWS ID# NJ 1023002

Community Water System Name: Borough of Stockton

Community Water System Address: 2 South Main, Stockton NJ 08551

1. CCRs must be mailed or electronically delivered to all bill-paying customers by July 1<sup>st</sup>. Provide date(s) of distribution: Mailed 6/20/1018

2. Please check the distribution method(s) utilized to reach your bill-paying customers.

- Mailed the CCR
- Mailed the direct URL of the CCR
- Embedded in an email message
- Attached as a PDF file in an email message
- Provided the website link (URL) in an email message
- Provided information on how a hardcopy of the CCR can be obtained

3. If the CCR was provided to customers electronically, provide the direct URL:  
 \_\_\_\_\_

4. Community Water Systems serving greater than or equal to 100,000 persons must post their CCR on the Internet. Date posted on the Internet and the URL: N/A

5. Community Water Systems must make a good faith effort to reach all appropriate non-bill paying customers. Check all of the methods that were utilized by your community water system.

Posted the CCR in public places (attach a list of locations)

Delivered copies of the CCR to several single bill addresses serving a significant number of people (example: apartment buildings, businesses and companies).

Advertised the availability of the CCR in news media (attach copy of announcement)

Published the CCR in a local newspaper (copy enclosed)

Other (List): \_\_\_\_\_

6. If your Community Water System sells water to another Community Water System, list the name and PWSID Number of the Community Water System(s) and the date the information was provided (due no later than April 1<sup>st</sup> unless mutually agreed upon by both systems):

N/A

7. Is the CCR being utilized to satisfy a Public Notice requirement pertaining to N.J.A.C. 7:10-7.4 for iron, manganese, or sodium?  No / Yes (circle one)

8. Is the CCR being utilized to satisfy a Tier 3 Public Notice requirement?  No / Yes (circle one)  
NOTE: If you circled "Yes", 1.) Be sure to submit the PN Certification Form for any Tier 3 PN requirement not previously submitted to DEP, 2.) Be sure to include the necessary standard language for a reporting violation, found at 40 CFR 141.205(d).

9. Check all distribution method(s) for the submittal to the Bureau of Safe Drinking Water (Bureau)\*.

Attached as a PDF file in an email message

Provided the website link (URL) in an email message

Mailed the CCR\*

\* NOTE: A non-submittal or late submittal to the Bureau will result in a reporting violation. As such, we recommend that you submit a copy using a means that can document the date of Bureau receipt, such as by email or by Certified mail.

10. The Certification below must be completed by the Community Water System.

I certify that the above referenced community water system has distributed the CCR in accordance with all applicable regulations. Furthermore, I certify that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state.

Signature: [Signature] Date: 6/18/2018

Print Name: GREGORY S. ENT Title: LICENSED OPERATOR

PWSID #: 1023001 Water System Name: BOROUGH OF STONINGTON

Email Address: WATEROPERATOR@STONINGTONBORO.NJ.US

Phone Number: 009.397.0070 Fax Number: 009.397.0070



# Annual Drinking Water Quality Report

## Stockton Borough Water Department

For the Year 2018, Results from the Year 2017

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

Our water source is wells. Our two wells draw groundwater from the Stockton Formation, which is a fractured bedrock aquifer system. Aquifer is another name for water contained in the rock and soil. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at [www.state.nj.us/dep/swap](http://www.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system at 609-397-0070 to obtain information regarding your water system's Source Water Assessment. This water system's source water susceptibility ratings, and a list of potential contaminant sources is included.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants:</b>						
Combined Radium 228 & 226 Tested Results Yr. 2012	N	Range = 1.5 Highest detect = 1.5	pCi/l	0	N/A	Erosion of natural deposits
<b>Inorganic Contaminants:</b>						
Arsenic Test results Yr. 2015	N	Range = 2.6 - 3.1 Highest detect = 3.1	ppb	N/A	5	Erosion of natural deposits; runoff from orchards from glass and electronics production wastes
Barium Test Results Yr. 2015	N	Range = 0.16 - 0.18 Highest detect = 0.18	ppm	2	2	Discharge of drilling wastes; discharge from refineries; erosion of natural deposits
Chromium Test results Yr. 2015	N	Range = ND - 0.6 Highest detect = 0.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Test Results December 2017 Result at 90 <sup>th</sup> Percentile	N	0.56 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride Test results Yr. 2015	N	Range = ND - 0.06 Highest detect = 0.06	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer aluminum factories
Lead Test Results December 2017 Result at 90 <sup>th</sup> Percentile	N	3.9 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Mercury (inorganic) Test results Yr. 2015	N	Range = ND - 0.08 Highest detect = 0.08	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from

Nickel Test results Yr. 2015	N	Range = 0.8 – 1.7 Highest detect = 1.7	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen) Test Results Yr. 2017	N	Range = 1.8 – 2.0 Highest detect = 2.0	ppm	10	10	Runoff from fertilizer use; leaching from septic sewage; erosion of natural deposits
Selenium Test results Yr. 2015	N	Range = 1.7 Highest detect = 1.7	ppb	50	50	Discharge from petroleum and metal refineries of natural deposits; discharge from mines
Thallium Test results Yr. 2015	N	Range = ND – 0.01 Highest detect = 0.01	ppb	0.5	2	Leaching from ore-processing sites; discharge electronics, glass, and drug factories
Disinfection Byproducts:				N/A	80	By-product of drinking water disinfection
TTHM Total Trihalomethanes Test results Yr. 2017	N	Range = 1 - 3 Highest detect = 3	ppb			
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine – Test results Yr. 2017		Average = 0.7 ppm		4.0 ppm		4.0 ppm

The Stockton Water Department routinely monitors for constituents in your drinking water according to Federal and State laws. The table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup> 2017. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Stockton Borough Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, synthetic organic chemicals and volatile organic chemicals. Our system received monitoring waivers for all of these types of contaminants.

## DEFINITIONS

In the "Test Results" table you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.  
Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.  
Action Level (AL) - the concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Recommended Upper Limit - (RUL) Recommended maximum concentration of secondary contaminants. RUL's are recommendations, not mandates.

Secondary Contaminant - Substances that do not have an impact on health. Secondary contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

If you have any questions about this report or concerning your water utility, please contact Greg Ent at 609-397-0070. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings. Meetings are held at Borough Hall, 2 South Main Street, on the last Monday of each month, at 7:30 p.m.

Please call our office if you have questions.

## Stockton Water Department - PWSID # NJ1023001

Stockton Water Department is a public community water system consisting of 2 wells.

This system's source water comes from the following aquifer: Stockton Formation

### Susceptibility Ratings for Stockton Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfecti Byprodu Precurso		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	
Wells - 2			2	1	1				2			2		2			2		2					2

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.